

Energy performance certificate (EPC)

257 High Street
CHATHAM
ME4 4BQ

Energy rating

C

Valid until: 21 June 2032

Certificate number: 0012-1232-9002-0326-6206

Property type

Retail/Financial and Professional Services

Total floor area

152 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

Energy efficiency rating for this property

This property's current energy rating is C.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO₂) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

10 | A

If typical of the existing stock

41 | B

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	26.5
Primary energy use (kWh/m ² per year)	259

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0260-1206-1402-9032-2200\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Robert Sims
Telephone	0203 397 8220
Email	hello@propcert.co.uk

Accreditation scheme contact details

Accreditation scheme	Quidos Limited
Assessor ID	QUID206427
Telephone	01225 667 570
Email	info@quidos.co.uk

Assessment details

Employer	Prop Cert
Employer address	<insert Employer/Trading Address>
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	20 June 2022
Date of certificate	22 June 2022
