

Energy performance certificate (EPC)

GROUND FLOOR
Osprey House
Crayfields Business Park
New Mill Road
ORPINGTON
BR5 3QJ

Energy rating

C

Valid until: 31 January 2029

Certificate number: 0990-3988-0311-0643-2040

Property type

B1 Offices and Workshop businesses

Total floor area

548 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

Energy efficiency rating for this property

This property's current energy rating is C.



Properties are also given a score. The larger the number, the more carbon dioxide (CO₂) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

26 | B

If typical of the existing stock

76 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
-------------------	---------------------------

Building environment	Air Conditioning
----------------------	------------------

Assessment level	3
------------------	---

Building emission rate (kgCO ₂ /m ² per year)	51.08
---	-------

Primary energy use (kWh/m ² per year)	302
--	-----

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9304-4049-0811-0203-6891\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Shayn Bennett
Telephone	01225753755
Email	info@greenrockenergy.co.uk

Accreditation scheme contact details

Accreditation scheme	Quidos Limited
Assessor ID	QUID206866
Telephone	01225 667 570
Email	info@quidos.co.uk

Assessment details

Employer	GreenRock Energy
Employer address	11 Dunkirk Business Park, Southwick, Trowbridge, Wilts, BA14 9NL
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	16 January 2019
Date of certificate	1 February 2019
