Energy performance certificate (EPC)				
298 HIGH STREET ORPINGTON BR6 0NF	Energy rating	Valid until:	8 July 2031	
		Certificate number:	2190-3183-9090-6207-6205	
Property type	Д	1/A2 Retail and Fina	ancial/Professional services	

Total floor area


83 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

31 B If typical of the existing stock 92 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	72.68
Primary energy use (kWh/m2 per year)	430

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/1617-9249-9002-0803-2606).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Nick Stevenson
Telephone	07736695824
Email	nick@stevenson24.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID207459
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	N Stevenson Consultancy
Employer address	Information not provided by the user
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	6 July 2021
Date of certificate	9 July 2021