# **Energy performance certificate (EPC)**

739 Sidcup Road LONDON SE9 3SA Energy rating

Valid until: 6 March 2029

Certificate number:

0070-8939-0321-6650-4070

Property type

A1/A2 Retail and Financial/Professional services

Total floor area


66 square metres

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### **Energy rating and score**

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

20 A

If typical of the existing stock

59 C

### Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	110.39
Primary energy use (kWh/m2 per year)	649

### **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/9867-4057-0312-0400-6901).

#### Who to contact about this certificate

#### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Aaron Lewis
Telephone	02084587444
Email	aaron@staygreen50.com

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID203098
Telephone	01225 667 570
Email	info@quidos.co.uk

#### About this assessment

Employer	CEC Energy Ltd.
Employer address	62 Woodville Road, London, NW11 9TN
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	6 March 2019
Date of certificate	7 March 2019